

MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
 OFFICE OF DRINKING WATER AND MUNICIPAL ASSISTANCE
**LEAD AND COPPER REPORT AND
 CONSUMER NOTICE OF LEAD RESULT
 CERTIFICATE FOR COMMUNITY WATER SUPPLY**



Issued under authority of 1976 PA 399, MCL 325.1001 *et al.*, and Administrative Rules, as amended.
 Failure to submit this information is a violation of Act 399 and may subject the water supply to enforcement penalties.

Administrative Rule R 325.10710d requires water supplies to report lead and copper monitoring information within 10 days after the end of the monitoring period. This form may be used to meet this requirement. Submit the information to the appropriate Department of Environmental Quality (DEQ) district office. For district office addresses, visit www.michigan.gov/deq and click on Locations.

1. Water Supply Name: St. Clair Shores
 2. County: Macomb 3. WSSN: 6280
 4. Population: 60,000 5. Monitoring Period: From: _____ To: _____
 6. Minimum # of Samples Required: 10 7. # of Samples Taken: 10
 8. Name of Certified Laboratory: GLWA - Quality Lab

9. SAMPLE CRITERIA:

Yes	No	Explain No responses in Comments block.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	a. Are the same sampling points used as in the previous monitoring period?
<input checked="" type="checkbox"/>	<input type="checkbox"/>	b. Are all samples from Tier 1 sites?
<input checked="" type="checkbox"/>	<input type="checkbox"/>	c. Are all samples from Tier 1, 2, or 3 sites giving Tier 1 priority?
<input type="checkbox"/>	<input type="checkbox"/>	d. If no Tier 1, 2, or 3 sites are available, do all sites have plumbing materials commonly found at other locations in the system?
<input checked="" type="checkbox"/>	<input type="checkbox"/>	e. Is the minimum number of lead service line samples taken (when applicable)?

For more information see *Instructions* paragraph 11, subparagraph "Sample Category."

Comments:

10. NAME:

Name: RUSSELL J. MILLER
 Title: Water Dept. Supervisor Phone: 586-445-5363 Date: 2-17-16
EX207

**Copper-Lead Study
 Sampling Period "special"
 Report 001**

Analyst: Brian Brown
 Report Date:

Sample Name	City	Address	Date Acidified	LEAD (ug/L)	Date Analyzed	COPPER (ug/L)	Date Analyzed
Note: Samples marked with "*" have been repeated as a higher dilution.							
6280-002	St. Clair Shores	Avalon	02/18/16	<2.0	02/19/16	22.8	02/19/16
6280-010	St. Clair Shores	Maison	02/18/16	<2.0	02/19/16	18.3	02/19/16
6280-012	St. Clair Shores	Sunnydale	02/18/16	<2.0	02/19/16	130.0	02/19/16
6280-017	St. Clair Shores	Maxine	02/18/16	<2.0	02/19/16	37.3	02/19/16
6280-024	St. Clair Shores	St. Gertrude	02/18/16	<2.0	02/19/16	<5.0	02/19/16
6280-028	St. Clair Shores	St. Gertrude	02/18/16	<2.0	02/19/16	29.2	02/19/16
6280-031	St. Clair Shores	Piwasant	02/18/16	<2.0	02/19/16	141.0	02/19/16
6280-054	St. Clair Shores	Francis	02/18/16	<2.0	02/19/16	8.2	02/19/16
6280-060	St. Clair Shores	Colony	02/18/16	<2.0	02/19/16	43.9	02/19/16
6280-062	St. Clair Shores	Alexander	02/18/16	<2.0	02/19/16	14.6	02/19/16

